

II.

COMMUNICATIONS

AUDIBLE ALARM - A loud whooping siren indicates the sound of the alarm.

PUBLIC ADDRESS SYSTEM - The building is equipped with a public address system that allows the building management and emergency personnel to communicate information to the occupants of the building in the event of an emergency.

EMERGENCY COMMUNICATION ANNOUNCEMENTS

Preliminary Investigation Script - ATTENTION - ATTENTION. This is the Building Management. An alarm has been activated on the _____ floor of the _____ (north or south) tower. Engineering is investigating the alarm. Please stand by for further instructions.

Evacuation Script - ATTENTION - ATTENTION. This is the Building Management. There is an emergency situation in the building. Please evacuate the building immediately using the nearest exit stairwell. Move slowly down the right side of the stairs, out of the building and across the street. Follow the directions of the Floor Wardens. DO NOT USE ELEVATORS.

False Alarm – ATTENTION - ATTENTION. The Engineer has reported a false alarm, please disregard. We repeat, the Engineer has reported a false alarm, please disregard. If you have left your floor you may return now.

All-Clear Script - ATTENTION - ATTENTION. This is the Building Management. The emergency situation has been corrected and we have been given the all-clear signal.

Power Outage – ATTENTION – ATTENTION. This is the Building Management. We have experienced an electrical power outage. We are in contact with the utility company to determine the cause of the outage, and the estimated time the power will be restored. Please stand by for further announcements.

Power Restored – ATTENTION – ATTENTION. This is the Building Management. The utility company has restored power to the building.